

Violation Notice

Date:	NC #(s):
nspector:	
nspector phone #:	

The object(s) referenced above have been found to be in violation of the Uniform Boiler & Pressure Vessel Act and Administrative Rules.

A detailed violation letter will soon be sent to the address we have listed for you in our database.

See the reverse side for important information.

Proof of service-hand delivery-NC#(s):
Inspector printed name:
Inspector signature:
Recipient printed name:
Recipient signature:
Date of delivery:

- 1. You have **60 days** to make corrective action and notify the Inspector that the object is ready for re-inspection. Upon notification, the Inspector will make a follow-up visit and close the violation(s) if satisfactory.
- 2. If you fail to notify the Inspector within **60 days** that the corrective action has been taken or that the object is no longer in service;
 - "Menace to Public Safety" tags may be placed on the object and in a location visible to the public and employees.
 - You will be subject to penalties pursuant to NC General Statutes Chapter 97, Article 7A, 95-69.19
- 3. If more than 60 days is needed for the corrective action, you must make a written request to the Chief Inspector prior to the 60-day deadline. This request shall include the NC number, reason for the request and the length of time needed to comply. The Chief Inspector will review the request and determine if an extension is warranted.



Boiler Safety Bureau

1101 Mail Service Center Raleigh, NC 27699-1101

919-707-7918

boiler.safety@labor.nc.gov

www.labor.nc.gov • 1-800-625-2267

IV.14.1934