



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Dawain Faison (dawain.faison@labor.nc.gov). to be uploaded to the intranet and the specific Unit.

Unit: ETTA	Location of Inspection: ORB 3rd-4 th Floor
Inspection Team:	Date of Inspection: 12/30/14
1. Jesse Mendoza	Unit Manager: Wanda Lagoe
2. Carlene Harris	Additional Comments:
3.	No update on electrical appliances issue from steering committee during last meeting so none were addressed during inspection. Reminded those present of not overloading the powerstrips.

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date): No overloaded powerstrips found. Carlene and I looked for potential tripping hazards and found carpet repairs glued. Need the stripping leading to Reggie's and Andy's cubicle secured. Will coordinate with building maintenance.			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Fire extinguishers inspected (identify by Serial #)
<input type="checkbox"/>		<input type="checkbox"/>	
Additional Comments, notations, and abatement information (including date): All fire extinguishers up to date on both floors. Defibrillator status OK.			

