



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (Amanda.Carroll@labor.nc.gov). To be uploaded to the intranet and the specific Unit.

Unit: ETTA	Location of Inspection: ORB 3 rd , 4 th , 5 th floors
Inspection Team:	Date of Inspection: September 24, 2018 – 3 rd Quarter
1. Carlene Harris	Unit Manager: Wanda Lagoe
2. James Washington	Additional Comments:

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation	
<input type="checkbox"/> Cords in walkways	<input type="checkbox"/> Extension cords used as permanent wiring
<input type="checkbox"/> Damaged cords (any type)	<input type="checkbox"/> Exposed energized parts
<input type="checkbox"/> Missing ground pin on electrical cord	<input type="checkbox"/> Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/> Excessively warm/overheated cords or equipment:	<input type="checkbox"/> Outlet missing cover or broken cover
	<input type="checkbox"/> Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date): Electric cords and outlets were in working order.	

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation	
<input type="checkbox"/> Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/> Blocked fire extinguishers
<input type="checkbox"/> Emergency Exit lighting is working correctly	<input type="checkbox"/> Exit doors in working condition
<input checked="" type="checkbox"/> Space heaters meet testing laboratories criteria	<input type="checkbox"/> Block Exit doors
<input type="checkbox"/> Flammable/Combustibles stored correctly	<input checked="" type="checkbox"/> Chemicals stored correctly
<input type="checkbox"/> Excessively warm/overheated cords or equipment:	<input checked="" type="checkbox"/> Fire extinguishers inspected (identify by Serial #): 4th Floor - AO1427 and AO1428 (monthly)
Additional Comments, notations, and abatement information (including date): We inspected several 'stand-up' desks that are now being used by ETTA employees. No issues were identified. Both fire extinguishers were replaced in June 2018. They are being inspected by the ORB Floor Monitors for each floor. Several of the AED's are being serviced. Signage stating where the nearest one is located on the AED cabinet. The carpet will be replaced in the building in the month of October. There were no fire hazards or other items identified.	