



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (Amanda.Carroll@labor.nc.gov). To be uploaded to the intranet and the specific Unit.

Unit: OSH Compliance West	Location of Inspection: Charlotte Field Office
Inspection Team:	Date of Inspection: 08/11/2021
1. Kevin Cosgrove	Unit Manager: Paul Sullivan
2.	Additional Comments:
3.	All items checked; no issues to report.

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date):			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	
<input type="checkbox"/>		<input type="checkbox"/>	
Additional Comments, notations, and abatement information (including date):			



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (amanda.carroll@labor.nc.gov) to be uploaded to the intranet and the specific Unit.

Unit: District 1	Location of Inspection: Asheville Office
Inspection Team:	Date of Inspection: August 30, 2021
1. Kristie Hall	Unit Manager: Kay Knezevich
2.	Additional Comments:
3.	Fire Extinguishers had an annual inspection in August 2021.

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapters used or two prong extension cord
Additional Comments, notations, and abatement information (including date):			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is NOT working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Fire extinguishers inspected (identify by Serial #) Kiddie Fire Extinguishers (#RD-379022 and #RD-379023)
Additional Comments, notations, and abatement information (including date): The AED (HeartStart FR2+ defibrillator) was checked, to include: located in designated location, no damage or missing parts, battery was charged, a spare battery was present, and AED pads are current.			



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (Amanda.Carroll@labor.nc.gov). To be uploaded to the intranet and the specific Unit.

Unit: OSH Compliance East	Location of Inspection: Lake Boone Trail – 1 st , 2 nd , 3 rd Floors; Parking Decks
Inspection Team:	Date of Inspection: August 31, 2021
1. Deborah Samad	Unit Manager: TBA (Nicole Brown)
2.	Additional Comments:
3.	** See below re: Light fixtures in West Stairwell.

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date):			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Fire extinguishers inspected (identify by Serial #) KL-719206; BX-749520; RX-347124; SX-011828; SL-128243; BA-820835.
Additional Comments, notations, and abatement information (including date): 8/31/21: ALL of the emergency lighting fixtures in the West Stairwell continue to FAIL when tested. It was reported in June 2021 that the landlord has informed BC Brown that the matter is being addressed.			



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (Amanda.Carroll@labor.nc.gov). To be uploaded to the intranet and the specific Unit.

Unit: Winston-Salem Compliance West Field Office	Location of Inspection: Winston-Salem Pinnacle Building
Inspection Team: James Dempsey	Date of Inspection: 8/13/2021
1.	Unit Manager: Ben Harris
2.	Additional Comments:
3.	

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation	
<input type="checkbox"/> Cords in walkways	<input type="checkbox"/> Extension cords used as permanent wiring
<input type="checkbox"/> Damaged cords (any type)	<input type="checkbox"/> Exposed energized parts
<input type="checkbox"/> Missing ground pin on electrical cord	<input type="checkbox"/> Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/> Excessively warm/overheated cords or equipment:	<input type="checkbox"/> Outlet missing cover or broken cover
	<input type="checkbox"/> Two prong adapters used or two prong extension cords
Additional Comments, notations, and abatement information (including date): All ok : 8/13/2021	

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation	
<input type="checkbox"/> Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/> Blocked fire extinguishers
<input type="checkbox"/> Emergency Exit lighting is working correctly	<input type="checkbox"/> Exit doors in working condition
<input type="checkbox"/> Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/> Block Exit doors
<input type="checkbox"/> Flammable/Combustibles stored correctly	<input type="checkbox"/> Chemicals stored correctly
<input type="checkbox"/> Excessively warm/overheated cords or equipment:	Fire extinguishers inspected (identify by Serial #) Ten fire extinguishers inspected (SA-772292, YP-234285, YE-208191, SL-102203, ZD-926241, X-530590, MR-669188, MR-669014, AB-847629, MR-669961) All ok-8/13/2021
Additional Comments, notations, and abatement information (including date): Defibrillation electrode pads (Phillips Adult / Child Multifunction Electrode Pads (2) Part # M3713A expires 2022-05-31, During recent power outage, it was noted that the emergency lighting in both stairwells had no power-hazardous to employees-during next power outage, CSHO will verify if this still an issue.	