



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (Amanda.Carroll@labor.nc.gov). To be uploaded to the intranet and the specific Unit.

Unit: Winston-Salem Compliance West Field Office	Location of Inspection: Winston-Salem Pinnacle Building
Inspection Team: James Dempsey	Date of Inspection: 02/11/2022
1.	Unit Manager: Ben Harris
2.	Additional Comments:
3.	

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapters used or two prong extension cords
Additional Comments, notations, and abatement information (including date): All ok : 02/11/2022			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Fire extinguishers inspected (identify by Serial #) Ten fire extinguishers inspected (SA-772292, YP-234285, YE-208191, SL-102203, ZD-926241, X-530590, MR-669188, MR-669014, AB-847629, MR-669961) All ok : 02/11/2022
Additional Comments, notations, and abatement information (including date): Defibrillation electrode pads (Phillips Adult / Child Multifunction Electrode Pads (2) Part # M3713A expires 2022-05-31, Defib battery replaced-12/21/21. During recent power outage, it was noted that the emergency lighting in both stairwells had no power-hazardous to employees-during next power outage, CSHO will verify if this still an issue.			



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (Amanda.Carroll@labor.nc.gov). To be uploaded to the intranet and the specific Unit.

Unit: OSH Compliance East	Location of Inspection: Lake Boone Trail 3 rd , 2 nd , 1 st floors and parking decks.
Inspection Team:	Date of Inspection: February 28, 2022
1. Deborah Samad	Unit Manager:
2.	Additional Comments:
3.	

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation		
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/> Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/> Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/> Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/> Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/> Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date):		

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation		
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/> Blocked fire extinguishers
<input checked="" type="checkbox"/>	Emergency Exit lighting is working correctly	<input type="checkbox"/> Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/> Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/> Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/> Fire extinguishers inspected (identify by Serial #): A 30378830; BA 820835; BX 749520; RX 347124; SX 011828; SL 128343.
Additional Comments, notations, and abatement information (including date): Emergency light fixture <u>failure</u>: above door from lab to elevator lobby.		



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (amanda.carroll@labor.nc.gov) to be uploaded to the intranet and the specific Unit.

Unit: District 1	Location of Inspection: Asheville Office
Inspection Team:	Date of Inspection: February 23, 2022
1. Kristie Hall	Unit Manager: Kay Knezevich
2.	Additional Comments:
3.	The Philips multifunction electrode pads for the HeartStart defibrillator expires 5/31/2022.

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapters used or two prong extension cord
Additional Comments, notations, and abatement information (including date):			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is NOT working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Fire extinguishers inspected (identify by Serial #) Kiddie Fire Extinguishers (#RD-379022 and #RD-379023)
Additional Comments, notations, and abatement information (including date): The AED (HeartStart FR2+ defibrillator) was checked, and it was in its designated location, there was no damage or missing parts, the battery was charged, and the AED pads were current.			



Employee Safety and Health Program

Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll (amanda.carroll@labor.nc.gov) to be uploaded to the intranet and the specific Unit.

Unit: Compliance - West	Location of Inspection: Charlotte
Inspection Team:	Date of Inspection: February 22, 2022
1. Beverly Stone	Unit Manager: Paul Sullivan
	Additional Comments:
2.	

Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation			
<input type="checkbox"/>	Cords in walkways	<input type="checkbox"/>	Extension cords used as permanent wiring
<input type="checkbox"/>	Damaged cords (any type)	<input type="checkbox"/>	Exposed energized parts
<input type="checkbox"/>	Missing ground pin on electrical cord	<input type="checkbox"/>	Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Outlet missing cover or broken cover
<input type="checkbox"/>		<input type="checkbox"/>	Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date): N/A			

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation			
<input type="checkbox"/>	Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/>	Blocked fire extinguishers
<input type="checkbox"/>	Emergency Exit lighting is working correctly	<input type="checkbox"/>	Exit doors in working condition
<input type="checkbox"/>	Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/>	Block Exit doors
<input type="checkbox"/>	Flammable/Combustibles stored correctly	<input checked="" type="checkbox"/>	Chemicals stored correctly
<input type="checkbox"/>	Excessively warm/overheated cords or equipment:	<input type="checkbox"/>	Fire extinguishers inspected (identify by Serial #)
Additional Comments, notations, and abatement information (including date): There was an unlabeled spray bottle of disinfectant in the janitor's closet. Found the original container for the disinfectant in the janitor's closet. Labeled the spray bottle of disinfectant with a permanent marker.			