



## Employee Safety and Health Program

### Unit and Field Office Inspection Form

Provide copy of this completed form to the Bureau Chief, and the Employee Safety and Health Program via Amanda Carroll ([Amanda.Carroll@labor.nc.gov](mailto:Amanda.Carroll@labor.nc.gov)). To be uploaded to the intranet and the specific Unit.

Unit: Winston-Salem Compliance West Field Office	Location of Inspection: Winston-Salem Pinnacle Building
Inspection Team: James Dempsey	Date of Inspection: 7/9/2021
1.	Unit Manager: Ben Harris
2.	Additional Comments:
3.	

### Inspection Information

Electrical Cords and Outlets: Check appropriate box when condition is identified and add notation	
<input type="checkbox"/> Cords in walkways	<input type="checkbox"/> Extension cords used as permanent wiring
<input type="checkbox"/> Damaged cords (any type)	<input type="checkbox"/> Exposed energized parts
<input type="checkbox"/> Missing ground pin on electrical cord	<input type="checkbox"/> Daisy chain (power strip plugged into another power strip)
<input type="checkbox"/> Excessively warm/overheated cords or equipment:	<input type="checkbox"/> Outlet missing cover or broken cover
	<input type="checkbox"/> Two prong adapter used or two prong extension cord
Additional Comments, notations, and abatement information (including date): All ok : 7/9/2021	

Fire Hazards and Egress: Check appropriate box when condition is identified and make notation	
<input type="checkbox"/> Items stored within 3 feet of a heater and/or heat source	<input type="checkbox"/> Blocked fire extinguishers
<input type="checkbox"/> Emergency Exit lighting is working correctly	<input type="checkbox"/> Exit doors in working condition
<input type="checkbox"/> Space heaters meet testing laboratories criteria (Identify)	<input type="checkbox"/> Block Exit doors
<input type="checkbox"/> Flammable/Combustibles stored correctly	<input type="checkbox"/> Chemicals stored correctly
<input type="checkbox"/> Excessively warm/overheated cords or equipment:	Fire extinguishers inspected (identify by Serial #) Ten fire extinguishers inspected (SA-772292, YP-234285, YE-208191, SL-102203, ZD-926241, X-530590, MR-669188, MR-669014, AB-847629, MR-669961) All ok-7/9/2021
Additional Comments, notations, and abatement information (including date): Defibrillation electrode pads (Phillips Adult / Child Multifunction Electrode Pads (2) Part # M3713A expires 2022-05-31, During recent power outage, it was noted that the emergency lighting in both stairwells had no power-hazardous to employees-during next power outage, CSHO will verify if this still an issue.	